



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAFT: Northshore (Inside) - Special
Laboratory ID: 16C2853-01

Report Date: 04/12/16 09:13
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name:
Sampled by:
Employed by:

Sample Date: 03/30/16 09:59
Sample Received: 03/30/16 15:00
User ID:
System Number:

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	<1.0	10	1	ug/L *	01032	EPA 218.6

- Water sample was taken after water had been filtered by customer's in house water filtration system.
- Customer uses a "PureMaster V-700" water filtration system purchased on line from Vitasalus.
- The Chrom 6 level was less than 1 ppb on the day we took the in house filtered water sample.

$$* 1 \text{ ug/L} = 1 \text{ ppb}$$



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAF⁷ Northshore (Outside) - Special
Laboratory ID: 16C2853-02

Report Date: 04/12/16 09:13
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name:
Sampled by: Barry Silva
Employed by:

Sample Date: 03/30/16 10:07
Sample Received: 03/30/16 15:00
User ID:
System Number:

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	12	10	1	ug/L *	01032	EPA 218.6

- Sample taken outside customers home.

- Pre in house filtration.

* 1 ug/L = 1 ppb