ADDENDUM NO. 1
to
SPECIAL PROVISIONS, PROPOSAL AND CONTRACT
FOR CONSTRUCTION OF

FY 25-26 ISOLATION VALVE PROJECT

HIDDEN VALLEY LAKE COMMUNITY SERVICES DISTRICT

DATE:	April 24, 2026
TO:	Plan Holders
SUBJECT:	Revision to Technical Specifications
BIDS DUE:	**May 5, 2026 @ 1:00 PM**

This Addendum forms a part of the Bidding and Contract Documents and modifies the Bid Documents as described below.

THE FOLLOWING REVISIONS SHALL BE MADE TO THE TECHNICAL SPECIFICATIONS:

1. Section 10-9 Insertion Valve, Subsection 10-9.04 Materials

   The second sentence shall be replaced with the following:

   Valves shall be designed for use in potable water systems and shall be rated for 250 psi maximum working pressure.

PLEASE SIGN THIS ADDENDUM IN THE SPACE PROVIDED BELOW AND INCLUDE THE SIGNED COPY OF THIS ADDENDUM WITH YOUR BID DOCUMENTS. NOTE THAT BID DOCUMENTS SUBMITTED WITHOUT A SIGNED COPY OF THIS ADDENDUM MAY BE CONSIDERED NON-RESPONSIVE AND MAY BE REJECTED.

By: Heidi E. Utterback _____ 04/24/26
Heidi E. Utterback, P.E. Date

The undersigned has received and read this addendum.

_____ _____
Contractor Name Signature

_____ _____
Name (printed) Date