



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

07 March 2016

Hidden Vly. Lake Community Service District

Attn: Dennis White

19400 Hartman Road

Hidden Valley Lake, CA 95467

RE: Source Chemical Monitoring

Work Order: 16B2120

Enclosed are the results of analyses for samples received by the laboratory on 02/24/16 15:45. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

DRAFT REPORT

DATA SUBJECT TO CHANGE



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Hidden Vly. Lake Community Service District
19400 Hartman Road
Hidden Valley Lake CA, 95467

Project: Source Chemical Monitoring
Project #: 1710015
Project Mgr: Dennis White

Reported:
03/07/16 14:04

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
DRAFT: Well 2 (002)	16B2120-01	Water	02/24/16 09:00	02/24/16 15:45
DRAFT: Well 3 (003)	16B2120-02	Water	02/24/16 09:07	02/24/16 15:45
DRAFT: Well 4 (004)	16B2120-03	Water	02/24/16 09:13	02/24/16 15:45
DRAFT: Well @ Treatment Plant (006)	16B2120-04	Water	02/24/16 08:45	02/24/16 15:45



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAFT: Well 2 (002)
Laboratory ID: 16B2120-01

Report Date: 03/07/16 14:04
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-002 WELL 02
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 02/24/16 09:00
Sample Received: 02/24/16 15:45
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	14	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAFT: Well 3 (003)
Laboratory ID: 16B2120-02

Report Date: 03/07/16 14:04
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-003 WELL 03 (STANDBY)
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 02/24/16 09:07
Sample Received: 02/24/16 15:45
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	7.8	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAFT: Well 4 (004)
Laboratory ID: 16B2120-03

Report Date: 03/07/16 14:04
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-004 WELL 04
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 02/24/16 09:13
Sample Received: 02/24/16 15:45
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	12	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: DRAFT: Well @ Treatment Plant (006)
Laboratory ID: 16B2120-04

Report Date: 03/07/16 14:04
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-006 WELL TREATMENT PLANT
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 02/24/16 08:45
Sample Received: 02/24/16 15:45
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	16	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267


Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.



Items for Project Manager Review

LabNumber

Analysis

Analyte

Exception
