



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

20 March 2017

Hidden Vly. Lake Community Service District

Attn: Dennis White

19400 Hartman Road

Hidden Valley Lake, CA 95467

RE: Source Chemical Monitoring

Work Order: 17C0793

Enclosed are the results of analyses for samples received by the laboratory on 03/08/17 15:55. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Sheri Speaks

Sheri L. Speaks For Robbie C. Phillips

Project Manager



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Hidden Vly. Lake Community Service District 19400 Hartman Road Hidden Valley Lake CA, 95467	Project: Source Chemical Monitoring Project #: 1710015 Project Mgr: Dennis White	Reported: 03/20/17 12:22
---	--	-----------------------------

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Well 3 (003)	17C0793-01	Water	03/08/17 10:10	03/08/17 15:55
Well 4 (004)	17C0793-02	Water	03/08/17 09:48	03/08/17 15:55
Well @ Treatment Plant (006)	17C0793-03	Water	03/08/17 09:13	03/08/17 15:55



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: Well 3 (003)
Laboratory ID: 17C0793-01

Report Date: 03/20/17 12:22
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-003 WELL 03 (STANDBY)
Sampled by: Sam G.
Employed by: Hidden Vly Lake CSD

Sample Date: 03/08/17 10:10
Sample Received: 03/08/17 15:55
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	<10	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	5.7	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: Well 4 (004)
Laboratory ID: 17C0793-02

Report Date: 03/20/17 12:22
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-004 WELL 04
Sampled by: Sam G.
Employed by: Hidden Vly Lake CSD

Sample Date: 03/08/17 09:48
Sample Received: 03/08/17 15:55
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	20	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	20	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: Well @ Treatment Plant (006)
Laboratory ID: 17C0793-03

Report Date: 03/20/17 12:22
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-006 WELL TREATMENT PLANT
Sampled by: Sam G.
Employed by: Hidden Vly Lake CSD

Sample Date: 03/08/17 09:13
Sample Received: 03/08/17 15:55
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	21	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	22	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

Work Order Chain of Custody Record

Lab No. 17C0793 Page of

4.0

Name: Hidden Valley Lake CSD		Project ID: Source Chemical Monitoring		Signature below authorizes work under terms stated on reverse side.												Analysis Request	Sample Notes	TAT	
Mailing Address: 19400 Hartmann Road Hidden Valley Lake, CA 95467		Project No: 1710015															Well # 2 is out of Service	24 hr <input type="radio"/>	
Project Contact (Hardcopy or PDF to): Dennis White dwhite@hiddenvalleylakesd.com		PO#																48 hr <input type="radio"/>	
																		Lab Approval Required	
Field Sampler - Print Name & Signature <i>Sam G. Sanders</i>		Sample Collection		Container				Preservative				Matrix				Cr 6 218.6 DW	Cr 200.8 DW	WO	1 wk <input type="radio"/>
Sample Identification		Date Time		40ml VOA	Poly	Amber	Sleeve	Na2S2O3	HNO3	Buffer	NaOH	None	Water	Soil				2 wk (standard) <input type="radio"/>	
Well 2 (002)					2			1	1				X		X	X	X	Lab Approval Required For Rush	
Well 3 (003)		3-8 10:10			2			1	1				X		X	X			
Well 4 (004)		3-8 9:48			2			1	1				X		X	X			
Well @ Treatment Plant (006)		3-8 9:13			2			1	1				X		X	X			
Relinquished by: <i>Sanders</i>		Received by: <i>[Signature]</i>		Date 3/8/17		Time 1235													
Relinquished by: <i>[Signature]</i>		Received by: <i>[Signature]</i>		Date 3/8/17		Time 1550													
Relinquished by:		Received by:		Date		Time													
Relinquished by:		Received by:		Date		Time													
Relinquished by:		Received by:		Date		Time													