



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

23 June 2016

Hidden Vly. Lake Community Service District

Attn: Dennis White

19400 Hartman Road

Hidden Valley Lake, CA 95467

RE: Source Chemical Monitoring

Work Order: 16F0298

Enclosed are the results of analyses for samples received by the laboratory on 06/02/16 15:20. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Sheri Speaks

Sheri L. Speaks For Robbie C. Phillips

Project Manager



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Hidden Vly. Lake Community Service District 19400 Hartman Road Hidden Valley Lake CA, 95467	Project: Source Chemical Monitoring Project #: 1710015 Project Mgr: Dennis White	Reported: 06/23/16 07:14
---	--	-----------------------------

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Well 2 (002)	16F0298-01	Water	06/02/16 08:32	06/02/16 15:20
Well 3 (003)	16F0298-02	Water	06/02/16 08:35	06/02/16 15:20
Well 4 (004)	16F0298-03	Water	06/02/16 08:26	06/02/16 15:20
Well @ Treatment Plant (006)	16F0298-04	Water	06/02/16 07:52	06/02/16 15:20



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: **Well 2 (002)**
Laboratory ID: 16F0298-01

Report Date: 06/23/16 07:14
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-002 WELL 02
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 06/02/16 08:32
Sample Received: 06/02/16 15:20
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	16	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	14	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: **Well 3 (003)**
Laboratory ID: 16F0298-02

Report Date: 06/23/16 07:14
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-003 WELL 03 (STANDBY)
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 06/02/16 08:35
Sample Received: 06/02/16 15:20
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	<10	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	6.9	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: **Well 4 (004)**
Laboratory ID: 16F0298-03

Report Date: 06/23/16 07:14
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-004 WELL 04
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 06/02/16 08:26
Sample Received: 06/02/16 15:20
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	22	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	19	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: Well @ Treatment Plant (006)
Laboratory ID: 16F0298-04

Report Date: 06/23/16 07:14
Laboratory Code: 1610

System Name: HIDDEN VALLEY LAKE CSD
Source Name: 1710015-006 WELL TREATMENT PLANT
Sampled by: Barry Silva
Employed by: Hidden Vly Lake CSD

Sample Date: 06/02/16 07:52
Sample Received: 06/02/16 15:20
User ID: RXR
System Number: 1710015

Data submitted to DDW via EDT

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium	15	50	10	ug/L	01034	EPA 200.8

Inorganic: Additional Analyses

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Chromium, hexavalent	13	10	1	ug/L	01032	EPA 218.6



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

**Work Order
 Chain of Custody Record**

Lab No. 16F0298 Page of

Name: Hidden Valley Lake CSD
 Project ID: Source Chemical Monitoring
 Mailing Address: 19400 Hartmann Road
 Hidden Valley Lake, CA 95467
 Project No: 1710015
 Project Contact (Hardcopy or PDF to):
 Dennis White
 dwhite@hiddenvalleylakecsd.com
 PO#

Signature below authorizes work under terms stated on reverse side.

Field Sampler - Print Name & Signature <i>BARRY SILVA / B.S.</i>	Sample Collection Date Time	Container			Preservative				Matrix			Cr6 218.6 DW	Cr 200.8 DW	WO	Analysis Request	Sample Notes	TAT	Lab Approval Required For Rush
		40ml VOA	Poly	Amber	Sleeve	Na2S2O3	HNO3	Buffer	NaOH	None	Water							
Well 2 (002)	6/2/16 8:32	2				1	1					X	X	X				24 hr <input type="radio"/> 48 hr <input type="radio"/> Lab Approval Required <input type="radio"/> 1 wk <input type="radio"/> 2 wk (standard) <input type="radio"/>
Well 3 (003)	6/2/16 8:35	2				1	1					X	X					
Well 4 (004)	6/2/16 8:40	2				1	1					X	X					
Well @ Treatment Plant (006)	6/2/16 7:52	2				1	1					X	X					

Relinquished by: <i>B.S.</i>	Received by:	Date: 6-2-16	Time: 8:45 AM
Relinquished by:	Received by:	Date: 6/2/16	Time: 1115
Relinquished by:	Received by:	Date: 6/2/16	Time: 1520
Relinquished by:	Received by:	Date:	Time:
Relinquished by:	Received by:	Date:	Time: